

Government of Bihar
public Health engineering Department


District level testing Laboratory:-Siwan

Sample Collected by:- JE Mairwa

Sample Receiving Date:- 02.06.2023

SL. No.	Date of Testing	Block	Village	Name of Scheme	Parameters															
					PH	Turb.	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	Fl	Mn	As	Total Coli
1	07.06.2023	Darauli	Don	J R Convent Don	7.98	1.2	-	165	265	64	-	72	260	0.23	0.88	45	0.35	0.24	0	<1.1
Desirable Limits					6.5-8.5	5.0	-	500	200	75	75	250	200	0.3	45	200	1	100	0.01	-
Permission Limits					8.5	NR	-		600	200	200	600	600	0.3	NR	400	1.5	0	NR	-

All Parameters are under distable limits


 Lab Assistant Chemist D.L.L
 P.L. H. Division, Siwan